

MATERIAL SAFETY DATA SHEET

JUL 26 1990 L-4602-B
September 1985



An explanation of the terms used herein may be found in OSHA 29 CFR 1910.1200,
available from OSHA regional or area offices.

(Essentially similar to U.S. Department of Labor Form OSHA-20
and generally accepted in Canada for information purposes)
Do Not Duplicate This Form. Request an Original.



I. PRODUCT IDENTIFICATION

PRODUCT	Helium		
CHEMICAL NAME	Helium	SYNONYMS	Helium-4
FORMULA	He	CHEMICAL FAMILY	Rare Gas
		MOLECULAR WEIGHT	4.003
TRADE NAME	Helium		

II. HAZARDOUS INGREDIENTS

For mixtures of this product request the respective component Material Safety Data Sheets. See Section IX.

MATERIAL (CAS NO.)	Wt (%)	1984-1985 ACGIH TLV-TWA (OSHA-PEL)	
Helium (7440-59-7)	100	Simple asphyxiant	(None currently established)

III. PHYSICAL DATA

BOILING POINT, 760 mm. Hg	-268.9°C (-452°F)	FREEZING POINT	-272°C (-457.6°F @ 25 Atm)
SPECIFIC GRAVITY (H ₂ O = 1)	Gas	VAPOR PRESSURE AT 20°C.	Gas
VAPOR DENSITY (air = 1)	0.138 @ 21°C (70°F)	SOLUBILITY IN WATER, % by wt.	Negligible
PERCENT VOLATILES BY VOLUME	100	EVAPORATION RATE (Butyl Acetate = 1)	Not applicable
APPEARANCE AND ODOR	Colorless gas at normal temperature and pressure; odorless.		

EMERGENCY PHONE NUMBER

IN CASE OF EMERGENCIES involving this material, further information is available at all times:
In the USA 304 — 744-3487 In Canada 514 — 645-5311
For routine information contact your local supplier

Union Carbide requests the users of this product to study this Material Safety Data Sheet (MSDS) and become aware of product hazards and safety information. To promote safe use of this product a user should (1) notify its employees, agents and contractors of the information on this MSDS and any product hazards and safety information, (2) furnish this same information to each of its customers for the product, and (3) request such customers to notify their employees and customers for the product of the same product hazards and safety information.

UNION CARBIDE CORPORATION LINDE DIVISION
UNION CARBIDE CANADA LIMITED LINDE DIVISION

IV. HEALTH HAZARD DATA

THRESHOLD LIMIT VALUE: Simple asphyxiant—ACGIH (1984-85).

EFFECTS OF A SINGLE (ACUTE) OVEREXPOSURE:

SWALLOWING — Unlikely route of exposure. This product is a gas at normal temperature and pressure.

SKIN ABSORPTION — No evidence of adverse effects from available information.

INHALATION — Asphyxiant. Moderate concentrations may cause headache, drowsiness, dizziness, excitation, excess salivation, vomiting and unconsciousness.

SKIN CONTACT — No evidence of adverse effects from available information.

EYE CONTACT — No evidence of adverse effects from available information.

EFFECTS OF REPEATED (CHRONIC) OVEREXPOSURE: No evidence of adverse effects from available information.

OTHER EFFECTS OF OVEREXPOSURE: None currently known. This product is an asphyxiant. Lack of oxygen can cause death.

MEDICAL CONDITIONS AGGRAVATED BY OVEREXPOSURE: A knowledge of the available toxicology information and of the physical and chemical properties of the material suggest that overexposure is unlikely to aggravate existing medical conditions.

SIGNIFICANT LABORATORY DATA WITH POSSIBLE RELEVANCE TO HUMAN HEALTH HAZARD EVALUATION: None currently known.

EMERGENCY AND FIRST AID PROCEDURES:

SWALLOWING — This product is a gas at normal temperature and pressure.

SKIN — Wash with soap and water.

INHALATION — Remove to fresh air. Give artificial respiration if not breathing. Give oxygen if breathing is difficult. Call a physician.

EYES — Flush with water.

NOTE TO PHYSICIAN: *There is no specific antidote. This product is inert. Treatment of overexposure should be directed at the control of symptoms and the clinical condition.*

V. FIRE AND EXPLOSION HAZARD DATA

FLASH POINT (test method)	Not applicable	AUTOIGNITION TEMPERATURE	Not applicable
FLAMMABLE LIMITS IN AIR, % by volume	LOWER Not applicable	UPPER	Not applicable

EXTINGUISHING MEDIA: Helium cannot catch fire. Use media appropriate for surrounding fire.

SPECIAL FIRE FIGHTING PROCEDURES: Evacuate all personnel from danger area. Immediately deluge containers with water spray from maximum distance until cool, then move containers away from fire area if without risk.

UNUSUAL FIRE AND EXPLOSION HAZARDS: Helium (high pressure gas) cannot catch fire. Container may rupture due to heat of fire. No part of a container should be subjected to a temperature higher than 52°C (approximately 125°F). Most containers are provided with a pressure relief device designed to vent contents when they are exposed to elevated temperature.

VI. REACTIVITY DATA

STABILITY		CONDITIONS TO AVOID: (See Section IX).
UNSTABLE	STABLE	
	X	

INCOMPATIBILITY (materials to avoid): None currently known. Helium is chemically inert.

HAZARDOUS DECOMPOSITION PRODUCTS: None.

HAZARDOUS POLYMERIZATION		CONDITIONS TO AVOID: None currently known.
May Occur	Will not Occur	
	X	

VII. SPILL OR LEAK PROCEDURES

STEPS TO BE TAKEN IF MATERIAL IS RELEASED OR SPILLED: Evacuate all personnel from danger area. Use self-contained breathing apparatus where needed. Shut off leak if without risk. Ventilate area of leak or move leaking container to well-ventilated area. Test area, especially confined areas, for sufficient oxygen content prior to permitting re-entry of personnel.

WASTE DISPOSAL METHOD: Slowly release into atmosphere outdoors. Discard any product, residue, disposable container or liner in an environmentally acceptable manner, in full compliance with federal, state and local regulations.

VIII. SPECIAL PROTECTION INFORMATION

RESPIRATORY PROTECTION (specify type): Select in accordance with OSHA 29 CFR 1910.134. Respirators shall be acceptable to MSHA and NIOSH.

VENTILATION	LOCAL EXHAUST — Preferred
	MECHANICAL (general) — Acceptable
	SPECIAL — Not applicable
	OTHER — Not applicable

PROTECTIVE GLOVES: Preferred for cylinder handling.

EYE PROTECTION: Select in accordance with OSHA 29 CFR 1910.133

OTHER PROTECTIVE EQUIPMENT: Metatarsal shoes for cylinder handling. Select in accordance with OSHA 29 CFR 1910.132 and 1910.133.

IX. SPECIAL PRECAUTIONS

CAUTION: High pressure gas. Use piping and equipment adequately designed to withstand pressures to be encountered. Can cause rapid suffocation due to oxygen deficiency. Store and use with adequate ventilation. Close valve when not in use and when empty. Do not strike arc on cylinder. Do not ground cylinder.

MIXTURES: When two or more gases, or liquefied gases are mixed, their hazardous properties may combine to create additional, unexpected hazards. Obtain and evaluate the safety information for each component before you produce the mixture. Consult an Industrial Hygienist, or other trained person when you make your safety evaluation of the end product. Remember, gases and liquids have properties which can cause serious injury or death. Be sure to read and understand all labels and other instructions supplied with all containers of this product.

When used in welding and cutting: Read and understand the manufacturer's instructions and the precautionary label on the product. See American Standard Z49.1, "Safety in Welding and Cutting" published by the American Welding Society, P.O. Box 351040, Miami, Florida 33135 and OSHA Publication 2206 (29CFR1910), U.S. Government Printing Office, Washington, D.C. 20402 for more detail. For further SAFETY AND HEALTH information, refer to Linde's free publication 52-529.

NOTE: Suitability for use as a component in underwater breathing gas mixtures is to be determined by or under the supervision of personnel experienced in the use of underwater breathing gas mixtures and familiar with the effects, methods, frequency and duration of use, hazards, side effects, and precautions to be taken. For safety information on general handling of compressed gas cylinders, obtain a copy of pamphlet P-1, "Safe Handling of Compressed Gases in Containers" from the Compressed Gas Association, Inc., 1235 Jefferson Davis Highway, Arlington, VA 22202.

OTHER HANDLING AND STORAGE CONDITIONS: Never work on a pressurized system. If there is a leak, close the cylinder valve, blow down the system by venting to a safe place, then repair the leak.

The opinions expressed herein are those of qualified experts within Union Carbide. We believe that the information contained herein is current as of the date of this Material Safety Data Sheet. Since the use of this information and these opinions and the conditions of use of the product are not within the control of Union Carbide, it is the user's obligation to determine the conditions of safe use of the product.



GENERAL OFFICES

IN THE USA:
Union Carbide Corporation
Linde Division
39 Old Ridgebury Road
Danbury, CT 06817-0001

IN CANADA:
Union Carbide Canada Limited
Linde Division
123 Eglinton Avenue East
Toronto, Ontario M4P 1J3

Other offices in principal cities all over the world.