



JUL 17 1996

MATERIAL SAFETY DATA SHEET NO. 53

AGA GAS, INC. (216) 642-6600
6225 OAKTREE BOULEVARD
P.O. BOX 94737
CLEVELAND, OH 44101-4737

Table with 2 columns: Product Name, Trade Name and Synonyms, Chemical Name and Synonyms, Issue Date and Revisions, CAS #, DOT I.D. No., DOT Hazard Class, Formula, Chemical Family. Contains details for Oxygen (CAS # 7782-44-7, UN 1072, Division 2.2, Formula O2, Oxidizer).

HEALTH HAZARD DATA

Table with 1 column: Health Hazard Data. Contains sections: TIME WEIGHTED AVERAGE EXPOSURE LIMIT (None established), SYMPTOMS OF EXPOSURE (Breathing high concentrations causes symptoms of hyperoxia), TOXICOLOGICAL PROPERTIES (The property is that of hyperoxia which leads to pneumonia), and RECOMMENDED FIRST AID TREATMENT (PROMPT MEDICAL ATTENTION IS MANDATORY).

Information contained in this material safety data sheet is offered without charge for use by technically qualified personnel at their discretion and risk. All statements, technical information and recommendations contained herein are based on tests and data which we believe to be reliable, but the accuracy or completeness thereof is not guaranteed and no warranty of any kind is made with respect thereto.

HAZARDOUS MIXTURES OF OTHER LIQUIDS, SOLIDS, OR GASES

Oxygen vigorously accelerates combustion. Contact with all flammable materials should be avoided. Some materials which are not flammable in air will burn in pure oxygen or oxygen-enriched atmospheres.

PHYSICAL DATA

BOILING POINT -297.3°F (-182.9°C)	LIQUID DENSITY AT BOILING POINT 71.23 lb/ft ³ (1141 kg/m ³)
VAPOR PRESSURE @ 70°F (21.1°C) Above the critical temp. of -181.1°F (-118.4°C)	GAS DENSITY AT 70°F, 1 atm .0828 lb/ft ³ (1.326 kg/m ³)
SOLUBILITY IN WATER Slightly	FREEZING POINT -361.8°F (-218.8°C)
EVAPORATION RATE N/A (Gas)	SPECIFIC GRAVITY (AIR=1) @ 70°F (21.1°C) = 1.11
APPEARANCE AND ODOR Colorless, odorless gas	

FIRE AND EXPLOSION HAZARD DATA

FLASH POINT (Method used) N/A	AUTO IGNITION TEMPERATURE N/A	FLAMMABLE LIMITS % BY VOLUME LEL N/A UEL N/A
EXTINGUISHING MEDIA Copious quantities of water for fires with oxygen as the oxidizer.		ELECTRICAL CLASSIFICATION Nonhazardous
SPECIAL FIRE FIGHTING PROCEDURES If possible, stop the flow of oxygen which is supporting the fire. If cylinders are involved in a fire, safely relocate or keep cool with water spray.		
UNUSUAL FIRE AND EXPLOSION HAZARDS Vigorously accelerates combustion.		

REACTIVITY DATA

STABILITY Unstable		CONDITIONS TO AVOID
Stable	X	None
INCOMPATIBILITY (Materials to avoid) All flammable materials		
HAZARDOUS DECOMPOSITION PRODUCTS None		
HAZARDOUS POLYMERIZATION May Occur		CONDITIONS TO AVOID
Will Not Occur	X	None

SPILL OR LEAK PROCEDURES**STEPS TO BE TAKEN IN CASE MATERIAL IS RELEASED OR SPILLED**

Evacuate all personnel from affected area. Use appropriate protective equipment. If leak is in user's equipment, be certain to purge piping with an inert gas prior to attempting repairs. If leak is in container or container valve, contact your closest supplier location or call the emergency telephone number listed herein.

WASTE DISPOSAL METHOD Do not attempt to dispose of waste or unused quantities. Return in the shipping container properly labeled, with any valve-outlet plugs or caps secured and valve protection cap in place to your supplier. For emergency disposal assistance, contact your closest supplier location or call the emergency telephone number listed herein.

RESPIRATORY PROTECTION (Specify type)		N/A	
VENTILATION Local Exhaust	LOCAL EXHAUST To prevent accumulation above 25 molar percent	SPECIAL	N/A
	MECHANICAL (Gen.)	OTHER	N/A
PROTECTIVE GLOVES	As required; any material		
EYE PROTECTION	Safety goggles or glasses		
OTHER PROTECTIVE EQUIPMENT	Safety shoes, safety shower		

SPECIAL PRECAUTIONS*

SPECIAL LABELING INFORMATION		DOT Hazard Class: Division 2.2	
DOT Shipping Name:	Oxygen, compressed	I.D. No.:	UN 1072
DOT Shipping Label(s):	Nonflammable Gas, Oxidizer		

SPECIAL HANDLING RECOMMENDATIONS

Use only in well-ventilated areas. Valve protection caps and valve outlet threaded plugs must remain in place unless container is secured with valve outlet piped to use point. Do not drag, slide or roll cylinders. Use a suitable hand truck for cylinder movement. Use a pressure reducing regulator when connecting cylinder to lower pressure (<3,000 psig) piping or systems. Do not heat cylinder by any means to increase the discharge rate of product from the cylinder. Use a check valve or trap in the discharge line to prevent hazardous back flow into the cylinder.

For additional handling recommendations, consult Compressed Gas Association's Pamphlets P-1, P-14, and G-4.

SPECIAL STORAGE RECOMMENDATIONS

Protect cylinders from physical damage. Store in cool, dry, well-ventilated area away from heavily trafficked areas and emergency exits and away from full or empty stored cylinders which contain flammable products. Do not allow the temperature where cylinders are stored to exceed 125F (52C). Cylinders should be stored upright and firmly secured to prevent falling or being knocked over. Full and empty cylinders should be segregated. Use a "first in - first out" inventory system to prevent full cylinders being stored for excessive periods of time.

For additional storage recommendations, consult Compressed Gas Association's Pamphlets P-1, P-14, and G-4.

SPECIAL PACKAGING RECOMMENDATIONS

Carbon steels and low alloy steels are acceptable for use at lower pressures. For high pressure applications use stainless steels, copper and its alloys, nickel and its alloys, brass, bronze, silicon alloys, Monel®, Inconel®, or beryllium. Lead and silver or lead and tin alloys are good gasketing materials. Teflon® and Kel-F® are the preferred nonmetal gaskets.

Special Note: It should be recognized that the ignition temperature of metals and non-metals in pure oxygen service decreases with increasing oxygen pressure.

OTHER RECOMMENDATIONS OR PRECAUTIONS

Oxygen should not be used as a substitute for compressed air in pneumatic equipment since this type generally contains flammable lubricants. Equipment to contain oxygen must be "cleaned for oxygen service." See Compressed Gas Association Pamphlet G-4.1.

Compressed gas cylinders should not be refilled except by qualified producers of compressed gases. Shipment of a compressed gas cylinder which has not been filled by the

(Continued on Page 4)

Oxygen

HEALTH HAZARD DATA

TIME WEIGHTED AVERAGE EXPOSURE LIMIT: (Continued)

(approximately 21 molar % of the atmosphere). OSHA 1993 PEL (8 Hr. TWA) =
None listed.

SPECIAL PRECAUTIONS

OTHER RECOMMENDATIONS OR PRECAUTIONS: (Continued)

owner or with his (written) consent is a violation of Federal Law (49CFR).

Always secure cylinders in an upright position before transporting them. NEVER transport cylinders in trunks of vehicles, enclosed vans, truck cabs or in passenger compartments. Transport cylinders secured in open flatbed or in open pick-up type vehicles.

Reporting under SARA, Title III, Section 313 not required.

NFPA 704 NO. for oxygen = 1 0 0 0X